

AMENDMENT NO. A00002

SOLICITATION: VA261-14-R-0483

PROJECT: 640-379

GENERAL

The following changes, additions or deletions shall be made to the following solicitation documents. All other terms and conditions shall remain unchanged.

I. **SPECIFICATIONS:** See ADDENDUM NO. 1

II. **DRAWINGS:** See ADDENDUM NO. 1

III. **OFFEROR QUESTIONS AND CLARIFICATIONS**

QUESTION: Please reference general notes 1 and 2 (AD102 & AD103). They state to remove finishes, ductwork, piping, raceways, etc., but there does not appear to be information on replacing/reinstalling these items. Is it the intent of the VA for these items to be reinstalled now or on a separate contract? Please advise.

ANSWER: The intent is to remove items required to access and complete work. The removed items shall remain removed and debris removed from job site. Reinstall will NOT be required by this contract.

QUESTION: Ref. Drawing AS402 & Specification 05 07 11, please provide the basis of design for the decorative glazed railing, is there a specific manufacturer the design is based on?

ANSWER: See Specification Section 05 70 11 for product information. No specific manufacturer is used or required. See Detail 1/AS603.

QUESTION: Can you extend the bid time to 2PM?

ANSWER: No, bid due date and time remain unchanged.

QUESTION: There seems to be a page missing in the Specs Volume 2 after Section 21 13 13 (PG 12). The last line reads "As Government review is for technical adequacy only, the installer remains responsible for" The following page begins with Section 22 05 11. Please Advise.

ANSWER: See attached complete Wet Pipe Sprinkler System Section: 21 13 13, pages 1-9.

Note: All offeror's are reminded that the VA SFTP website will NOT be utilized to publicize specifications, drawings, or changes to this solicitation. All information will be provided by FBO.